

Cold Springs Ranch

High Level Electrical Master Plan

September 2016

Intermountain Consumer Professional Engineers, Inc. 1145 East South Union Avenue Midvale, Utah 84047



TABLE OF CONTENTS

REPORT		
High Level Electrical Master Plan	 	1
TABLES		
Table 1 – Summary	 	
Table 2 – Circuit Loads		
DRAWINGS		
Land Use Plan		
F100 Site Plan		

COLD SPRINGS RANCH

High Level Electrical Master Plan

PURPOSE

The purpose of this report is to develop an estimate of the load that can be expected for the proposed Cold Springs Ranch development. Also included are recommendations for a new substation and the associated main trunk feeders that would be required to serve the development. The information provided is based on the current Land Use Plan developed by LEI.

LOAD ESTIMATES

Load estimates were based on the unit counts and densities shown on the Land Use Plan dated 9/20/16. Additional information was also obtained from discussions with LEI and Gardner Company. The location of apartments, townhomes, and single family dwellings were identified. Area MD #1 was identified as the location of a stake center. It was indicated that a hospital would be installed in commercial area Comm #1. The other two commercial areas are assumed to be a mix of small retail stores and office buildings, but specifics were not available at this time.

Typical unit loads (kW/unit) were used for the various load types. Loads for each development area were developed. Table 1 provides a summary of the anticipated load level for each area as well as the overall development. It should be noted that two load levels are identified. The first is for the "Low Range" unit counts indicated on the land use plan and the second is for the "High Range" unit counts. As can be seen a load range of between approximately 7 MW and 13 MW can be expected for the complete development of the area.

Area MD #1 is shown as a Stake Center for purposes of load estimation since it was indicated a stake center would be the most likely use of the property. There is also the chance that the area would be single family homes. Single family homes on the "Low Range" plan would be a smaller load than what is shown. Single family homes on the "High Range" plan would be similar to the load of the Stake Center.

A new substation is proposed to be built in area HD #5. For purposes of load estimation, two acres of area HD #5 have been shown for the substation.

The estimated loads are general in nature and are to be used for initial planning purposes only. As additional plans and details become available the load levels in each area should be reevaluated. Loads may be higher or lower than what is indicated based on the final building types that are constructed.

EXISTING LEHI AND RMP ELECTRICAL FACILITIES

RMP has two double circuit transmission lines that cross through the development just west of area LD #1. The line on the west is a double circuit 345 kV line and the line on the east is a double circuit 138 kV line.

There is a Lehi City 12.47 kV double circuit distribution line which runs along the north side of 2100 North. Future circuits would feed the area between Cold Springs Ranch and 2100 North and eventually provide tie points to those circuits. Across the river to the east and southeast there are Lehi City 12.47 kV distribution circuits. Two circuits feeding Cold Springs Ranch would cross the river and have tie points with those circuits in the future. The western boundary of Cold Springs Ranch is the Lehi City limits. The west half of the southern boundary of Cold Springs Ranch is the Lehi City limits. The existing Lehi circuits to the east that are closest to Cold Springs Ranch are near capacity and do not have capacity to serve the Cold Springs Ranch load.

REQUIRED FACILITY ADDITIONS

Substation

With the above in mind a new substation would be required to serve the development. The substation is proposed to be located in area HD #5. The substation is proposed to be fed from a new 138 kV line running parallel to the west



side of the existing RMP right of way. The new 138 kV line would need to be installed from the substation to a new substation that is planned just north of 2100 North. The substation would be configured as a two bay (transformer) substation with capability to have 6 to 8 distribution circuits feeding from the substation. A configuration similar to the recently completed Littlefield substation would be anticipated for this location.

Distribution Circuits

Three main underground distribution circuits from the new substation would be used to feed Cold Springs Ranch. Two of the circuits would also be used to feed future load across the river to the east and southeast of the development and to provide ties to existing circuits in those areas. Three additional future circuits would be used to feed future load north of Cold Springs Ranch up to 2100 North and would provide ties to circuits near 2100 North.

Drawing E100 shows the proposed main feeder or "backbone" circuits that would be required to serve Cold Springs Ranch. It is assumed that the main circuits indicated would be 600 A, 12.47Y/7.2 kV feeders. The layout provides for tie points between circuits to allow for contingency or maintenance circuit configurations. Table 2 is a load estimate by circuit and development area. Three distribution circuits are planned to serve the Cold Springs Ranch area.

Additional internal single and three phase feeders would be required within each development area. The design for these areas would be determined as part of the detailed development and plat approval process.

TIMING OF REQUIRED IMPROVEMENTS

It has been indicated that the hospital in commercial area Comm #1 would be installed first. The order in which to develop the residential areas and the other commercial areas has yet to be determined. The economy and the demand for various types of development would determine the development sequence. Close coordination with Lehi will be required as the development process progresses to assure the proper level of service is maintained to the customers.

As has been previously discussed above there is little if any capacity in the circuits which currently feed areas near Cold Springs Ranch. As such the substation would need to be completed as soon as practical to serve the new development. The substation would typically take 12-18 months to complete and put into service. In the interim Lehi may be willing to serve a small amount of load in Cold Springs Ranch.

SUMMARY

The estimated load for the new Cold Springs Ranch development would be between approximately 7 MW and 13 MW depending on final densities and building types served. There is little if any capacity in the Lehi circuits which currently feed areas near Cold Springs Ranch. As such a new substation would be required to be constructed as soon as development is started. Three distribution circuits would be required to meet the load demands of the development.

TABLE 1

COLD SPRINGS RANCH

Electrical Load Estimate

9/22/2016

Less Dense Plan More Dense Plan Est. Est. # Est. Avg. Est. Est. Est.# Est. Avg. Est. Area Description Type/Notes Acres Density of Units kW/Unit Load (kW) Density of Units kW/Unit Load (kW) Comm #1 Commercial 19.97 1,500.0 2,000.0 Hospital 1,500 2.000 Commercial 12 Comm #2 Retail/Office 23.12 0.3 100.0 700 0.5 100.0 1,200 Comm #3 Commercial Retail/Office 8.40 0.3 3 100.0 300 0.5 100.0 400 VHD #1 Very High Density Apartments 12.76 12.0 153 5.5 840 20.0 255 5.5 1,400 VHD #2 12.0 57 5.5 310 5.5 520 Very High Density Apartments 4.71 20.0 94 HD #1 12.21 7.0 85 6.0 510 12.0 147 High Density Townhomes 6.0 880 HD #2 8.66 7.0 61 6.0 370 12.0 104 6.0 620 **High Density** Townhomes HD #3 High Density Townhomes 4.64 7.0 32 6.0 190 12.0 56 6.0 340 75 HD #4 High Density Townhomes 10.70 7.0 6.0 450 12.0 128 6.0 770 7.0 550 **High Density** Townhomes 7.66 54 6.0 320 12.0 92 6.0 *HD #5 Substation Substation 2.00 30.0 30 50.0 50 **MD #1 5.05 200.0 200 250.0 250 Stake Center Stake Center MD #2 Medium Density Single Family 20.43 3.0 61 6.5 400 8.0 163 6.5 1,060 MD #3 22 Medium Density Single Family 7.49 3.0 6.5 140 8.0 60 6.5 390 MD #4 50 8.0 Medium Density Single Family 16.51 3.0 6.5 330 132 6.5 860 MD #5 Single Family 21.49 Medium Density 3.0 64 6.5 420 8.0 172 6.5 1,120 LD #1 Low Density Single Family 22.85 2.0 46 7.5 350 4.0 91 7.5 680 Public OS Public Open Space Park 48.40 30.0 30 50.0 50 11.35 Private OS Private Open Space Club House/Park 30.0 30 50.0 50 **TOTALS** 268.40 775 7.420 1.515 13,190

^{*}A new substation is proposed to be built in area HD #5. For purposes of load estimation, two acres of area HD #5 have been shown for the substation.

^{**}MD #1 is shown as a stake center, but it could possibly be single family homes. Single family homes on the "Low Range" plan would be a smaller load. Single family homes on the "High Range" plan would be similar to the load of the stake center.

TABLE 2
Estimated Circuit Loadings (kW)

Circuit 1 - New URD

Area	Less Dense	More Dense
Comm #1	1,500	2,000
Comm #2	700	1,200
VHD #1	840	1,400
VHD #2	310	520
HD #1	510	880
MD #1	200	250
MD #3	140	390
***************************************	***************************************	000000000000000000000000000000000000000
Total	4,200	6,640

Circuit 2 - New URD

Area	Less Dense	More Dense
Comm #3	300	400
HD #2	370	620
HD #3	190	340
HD #4	450	770
MD #2	400	1,060
Total	1,710	3,190

Circuit 2 would also cross the river to the southeast to feed future load and tie into existing Lehi circuits.

Circuit 3 - New URD

Area	Less Dense	More Dense
HD #5	350	600
MD #4	330	860
MD #5	420	1,120
LD #1	350	680
Public OS	30	50
Private OS	30	50
***************************************	***************************************	***************************************
Total	1,510	3,360
0: :: 0 :: 1		

Circuit 3 would also cross the river to the southeast to feed future load and tie into existing Lehi circuits.

Circuit 4 - Future

Circuit 4 would feed future load to the northwest and tie into Lehi circuits along 2100 North.


Circuit 5 - Future

Circuit 5 would feed future load to the north and tie into Lehi circuits along 2100 North.

Circuit 6 - Future

Circuit 6 would feed future load to the northeast and tie into Lehi circuits along 2100 North.





3. RESIDENTIAL UNITS MAY BE TRANSFERRED TO THE COMMERCIAL ZONE FROM VHD. MIN 8 UNITS PER

4. ANY AREA THAT IS NOT DEVELOPED TO BE LEFT OR RETURNED TO ORIGINAL CONDITION. 5. IF THE NEIGHBORHOOD COMMERCIAL ZONE IS NOT USED THE UNDERLYING ZONING APPLIES.

6. LOCAL ROADS SHOWN ARE CONCEPTUAL AND FINAL LOCATION MAY VARY.

7. ADDITIONAL 12 UNITS PROVIDED FOR CONSTRUCTION OF PEDESTRIAN BRIDGE.

ACRE. MUST MAINTAIN 70% OF COMMERCIAL AREA.

- A Utah Corporation -

ENGINEERS SURVEYORS

PLANNERS

3302 N. Main Street Spanish Fork, UT 84660 Phone: 801.798.0555 Fax: 801.798.9393 office@lei-eng.com www.lei-eng.com

RANCH

6

				PROPOSED DENSITY		PROPOSED UNITS	
			Low Range	High Range	Low Range	High Range	
LAND USE	ACRES	% OF NET AREA	(units/acre)	(units/acre)	(Units)	(Units)	
Gross Area	292.19						
Master Plan Roads	10.70						
Wetland Area	13.67						
Floodplain Area	22.28						
Wetland-Floodplain overlap	4.76						
NET AREA	250.30						
NET AREA (including 17.52 acres of floodplain open space)	267.82						
COMMERCIAL (Net areas without MP Roads)*	51.41	19.2%				150	
VHD	17.71	6.6%					
VHD #1	12.90	4.8%	12	20	155	258	
VHD #2	4.81	1.8%	12	20	58	96	
HD	46.45	17.3%					
HD #1	12.81	4.8%	7	12	90	154	
HD #2	8.73	3.3%	7	12	61	105	
HD #3	4.62	1.7%	7	12	32	55	
HD #4	10.64	4.0%	7	12	74	128	
HD #5	9.65	3.6%	7	12	68	116	
MD (minimum lot size: 3,780 s.f.)	71.19	26.6%					
MD #1	5.44	2.0%	3	8	16	44	
MD #2	20.51	7.7%	3	8	62	164	
MD #3	7.50	2.8%	3	8	23	60	
MD #4	16.40	6.1%	3	8	49	131	
MD #5	21.34	8.0%	3	8	64	171	
LD	23.18	8.7%					
LD #1	23.18	8.7%	2	4	46	93	
TOTAL OPEN SPACE AREA	57.88	21.6%					
Public Open Space	46.80	17.5%	1				
		4.1%					

* Includes to CL of Non-master plan roads ** Includes commercial area of 150 ERU's

REVISIONS

LEI PROJECT #: 2015-0125

BAP CHECKED BY:

SCALE:

1" = 250'

DATE:

1/11/2018

