



NOTES:

1. DEVELOPER/CONTRACTOR SHALL PROVIDE AND INSTALL ALL REQUIRED CONDUITS, AS SHOWN ON THE CIRCUIT ROUTING PLANS.
2. SECONDARY JUNCTION BOXES AND COMMUNICATION BOXES SHALL BE PROVIDED BY LEHI AND INSTALLED BY DEVELOPER/CONTRACTOR.
3. SEE CIRCUIT PLAN FOR EQUIPMENT LOCATIONS. EQUIPMENT SHALL BE CENTERED ON LOT LINES TO THE EXTENT POSSIBLE. OTHER LOCATIONS AS REQUIRED OR SHOWN ON THE CIRCUIT ROUTING PLAN.
4. DO NOT OBSTRUCT ACCESS TO POWER BOXES; MAINTAIN 3' CLEAR EXCEPT AS NOTED. PROVIDE 10' CLEARANCE ON CABINET ACCESS SIDES.
5. LEHI POWER SHALL PROVIDE, PULL & TERMINATE CONDUCTORS.
6. BASES AND BOXES SHALL BE PLACED ON FULL DEPTH COMPACT ENGINEERED FILL - COMPACTED TO 95% MAX DENSITY. EXTEND COMPACTED BASE MATERIAL AS REQUIRED TO MAINTAIN STABLE SUPPORT. REFER TO 4.2.1
7. EQUIPMENT BASES SHALL BE SET LEVEL AND ALIGNED WITH THE WALK OR ADJACENT ENTITIES TO PROVIDE A NEAT APPEARANCE.
8. CONDUIT AND EQUIPMENT SHALL BE PLACED AFTER CURB, GUTTER AND WALK TO ASSURE CORRECT PLACEMENT VERTICALLY AND HORIZONTALLY WITHIN THE EASEMENT.
9. FOR DEVELOPMENT WITHOUT WALKS, PLACE EQUIPMENT 3' MINIMUM 5' MAXIMUM BEHIND CURB.



REQUIREMENTS & STANDARDS
SECONDARY
JUNCTION BOX
(SECONDARY PEDESTAL)
(LOCATIONS IN THE P.U.E.)

DWG: **4.1.2**

REV. 1.00

BY: GWK/BT

DATE: 6/23/20